

**Specification of product analysis:**

TEST DESCRIPTION	TEST METHOD	SPECIFICATION	TEST RESULT
		Sample Point> Sample Nr>	#G1 Burner Fuel
Density @ 20 deg. C, kg/l	ASTM D7777	Report	0.885
Flash point, deg. C	ASTM D93	Report	85.0
Water content, %	ASTM D95	Report	0.2
Sulphur content, %	ASTM D7039	Report	0.6
Viscosity @ 40 deg. C, cSt	ASTM D445	Report	45
Ash content, %	ASTM D482	Report	0.7
Gross Calorific Value, MJ/kg	ASTM D240	Report	44
Nett Calorific Value MJ/kg	*Calculation	Report	42

You are welcome to contact us on 083 281 3243 should you require any further information.

Kind Regards



**Piere Coetzer**  
Director



environmental affairs  
Department  
Environmental Affairs  
REPUBLIC OF SOUTH AFRICA



GWIS Registration



Ekurhuleni  
METROPOLITAN MUNICIPALITY

Municipal Waste License



Rose Foundation Member